



中国国家强制性产品认证证书



证书编号: 2020322316001978

认证委托人名称: 图尔克(天津)传感器有限公司
认证委托人地址: 天津经济技术开发区渤海路34号
生产者名称: 汉斯图尔克有限公司
生产者地址: 鲁尔区米尔海姆威茨雷本大街7号
生产企业名称: 维尔纳尔图尔克有限公司
企业地址: Kirchloeber Weg 7, 58553 Halver, Germany

产品名称: 隔离式安全栅
系列、规格、型号: IMX12-CD01-2R-2U-0/La
标准: GB 3836.1-2010、GB 3836.4-2010、GB 3836.8-2014、
GB 12476.1-2013、GB 12476.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年9月25日 有效期至: 2025年9月24日

首次发证日期: 2020年9月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



SITIIAS
Worldwide Access

CERTIFICATE NO: 2020322316001978

APPLICANT: Turck (Tianjin) Sensor Co., Ltd.
ADDRESS: No.34 Bohai Road, TEDA, Tianjin, P.R.China
MANUFACTURER: Hans Turck GmbH & Co. KG
ADDRESS: Witzlebenstr. 7, 45472 Mülheim an der Ruhr
FACTORY: Werner Turck GmbH & Co.,KG
ADDRESS: Kirchlocher Weg 7, 58553 Halver, Germany

PRODUCTNAME: Relay coupler device
SERIES,SPECIFICATION,MODEL: IMX12-CD01-2R-2U-0/La
STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 3836.8-2014、
GB 12476.1-2013、GB 12476.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 25, 2020

Valid until: September 24, 2025

Date of original certification:September 25, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sttiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001266



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322316001978

附件

产品名称: 隔离式安全栅

型号规格: IMX12-CD01-2R-2U-0/L *a*

a 代表端子形式, 可为空白(螺丝端子)或/CC(弹簧端子)。

防爆标志: [Ex ia Ga]IIC, [Ex iaD],

Ex nA [ia Ga]IICT4Gc,

Ex nA [iaD]IICT4,

Ex nA nCIIC T4 Gc(仅适用于继电器版本)

电气参数: 非本安端的电气安全参数:

接线端子代号	电气安全参数
输入: 9-10 11-12 13-14	U = 0~30V d.c., 0.3W/通路 Um: 250V a.c. / d.c

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322316001978

附件

本安输出端本安（继电器输出：1~8）参数如下：

最高输出电压 U_o (V)	最大输出电流 I_o (mA)	最大输出功率 P_o (mW)	最大内部等效参数	
			C_i (μ F)	L_i (mH)
0	0	0	0	0

	最高输入电压 U_i (V)	最大输入电流 I_i (A)
继电器输出1: 6-7, 6-8 继电器输出2: 5-3, 5-4 继电器输出3: 5-1, 5-2	60	2

非本安输出端非本安（继电器输出：1~8）参数如下：

	电气安全参数
继电器输出1: 6-7, 6-8 继电器输出2: 5-3, 5-4 继电器输出3: 5-1, 5-2	$U=250V$ a.c., $I=2A$, $S=500VA$, AC15 $U=230V$ d.c., $I=0.18A$, resistive load resp. $U=30V$ d.c., $I=2A$, resistive load $P=60W$

批准:



上海仪器仪表自控系统检验测试所有限公司